

In the Superior Court of the State of California
in and for the County of Shasta

CERTIFICATE OF PUBLICATION
RECORD SEARCHLIGHT

REDDING CITY OF
777 CYPRESS AVE
REDDING CA 96001

REFERENCE: 00600008 MARCIA AMES
6688702 DATE: JULY 21, 200


State of California
County of Shasta

I hereby certify that the Record Searchlight is a newspaper of general circulation within the provisions of the Government Code of the State of California, printed and published in the City of Redding, County of Shasta, State of California; that I am the principal clerk of the printer of said newspaper; that the notice of which the annexed clipping is a true printed copy was published in said newspaper on the following dates, to wit;

PUBLISHED ON: 07/21

FILED ON: 08/07/09

I certify under penalty of perjury that the foregoing is true and correct,
at Redding, California on the above date.



RECORD SEARCHLIGHT
1101 Twin View Blvd, Redding, CA 96003



DATE: July 21, 2009
SUBJECT: LEGAL NOTICE CITY OF REDDING MUNICIPAL UTILITIES
SIGNIFICANT NON-COMPLIANCE OF INDUSTRIAL WASTE
PRETREATMENT REQUIREMENTS IN 2008

Listed below is a report of significant non-compliance (SNC) of industrial wastewater discharge limitations as required by the General Pretreatment Regulations (CFR) 403.8(f)(2)(vi) to annually publish any industrial users which were determined to be in SNC with applicable pretreatment requirements during the previous calendar year. SNC violations for discharges to the City of Redding Wastewater Treatment System in calendar year 2008 are as follows:

The industrial wastewater from Ameritech Industries located in Redding, CA exceeded the federal metal finishing limits at 40 CFR 433.17 for cadmium concentration on 9/2/08. Ameritech has had an exemplary record of discharge compliance since 2007, therefore this was an isolated event possibly due to construction in the room where parts are washed. City staff did not promptly review the data in order to respond by verifying the sample result and re-sampling the discharge. The discharge is approximately 25 gallons per day and is not a significant source of metal bearing waste in the sewer system. Re-sampling on 11/4/08, 2/2/09, 2/9/09, and 5/16/09 proved that the cadmium concentrations were back to acceptable levels.

The industrial wastewater from Aramark Industrial Services= industrial laundry facility in Redding, CA exceeded the City of Redding's standards for Oil and Grease concentration under RMC 14.16.535-18 on 2/27/08, 5/16/08 and 9/3/08. Aramark has been working cooperatively with the City on this issue. Oil and grease concentrations have been in compliance with the City's limits during wastewater testing on 11/8/08, 2/19/09, 4/2/09, and 5/27/09. Reductions have been achieved using Best Management Practices. If non-compliance reoccurs, a treatment system will be installed to remove additional oil and grease from the wastewater.

Please contact Marcia Ames, City of Redding Industrial Waste Supervisor for further information: P.O. Box 496071, Redding CA 96049-6071, Tel: 530-224-6049, email: mames@ci.redding.ca.us
Published July 21, 2009

6688702